



INSTITUT PRO TESTOVÁNÍ A CERTIFIKACI, a. s.
(Institute for Testing and Certification)
ZLÍN - CZECH REPUBLIC – www.itczlin.cz

TESTIMONIAL No. 16 011

confirms that the product

Paralatt, type: 125

manufactured by the company:

Aquaba Energie Centrum a.s.

Příčná 1045/2, 419 01 Duchcov, Czech Republic
IČ: 25475576

reaches for the below mentioned parameters the following values:

Property	Test method	Measuring unit	Test result
Slip resistance	ČSN EN 13845, Annex C	Degree (°)	22.0
- Classification according to ČSN EN 13845		Class	B
- Classification according to DIN 51097			
Mold resistance	ČSN EN ISO 846, Method A	Rate	4
Compressive load-bearing capacity	ČSN EN ISO 604	kN.m ⁻²	1284

The Certificate is issued on the basis of the following document:

- Final report No. j. **463500071/2016**, issued by ITC a. s. Zlín on 2016-06-10

Terms of the testimonial use and related information:

1. *The certificate applies only to the above mentioned models of the product.*
2. *The certificate remains valid unless there are changes of the manufacturing technology, applied standards or relevant regulations, but at the latest until the expiry date of the validity.*
3. *Validity of the testimonial can be verified on www.itczlin.cz.*

Issued in Zlín on : 2016-06-10
Valid until: 2019-06-30


Ing. Pavel Vaněk
Director of Certification Division

